

LANSING BOARD OF
WATER & LIGHT

Water T&D Construction Standard

METER SETTINGS PER JURISDICTIONAL AREA

APPLICATION: Reference the correct style meter setting to the appropriate jurisdictional area (Township or City).

All water meter settings shall be installed by an LBWL Water Field Inspector (WFI). All water meters will be supplied by LBWL and installed by either a Customer Accounts Representative (CAR) or a WFI.

"Customer Choice" for service line installation is available to all jurisdictional agencies.

The Standard for new residential service line installations consist of a 1" copper tube service line with an indoor meter setting having a 3/4" meter.

As of 7/1/2006, the 3/4" single yoke meter setting is the Standard meter setting for all jurisdictional agencies except for Delhi Twp.. The horn style meter setting is available only for maintenance replacement or new installations that require the vertical alignment between the service line inlet and the house plumbing outlet.

Standard Meter Setting

3/4" meter set, single yoke

Jurisdictional Agency

Alaiedon Twp.

Bath Twp.

City of DeWitt

City of Lansing

Delta Twp.

DeWitt Twp.

Lansing Twp.

Watertown Twp.

Windsor Twp.

3/4" meter set, double yoke

Delhi Twp.

Director of Engineering

DeWood

Date: 8/2/06

Director of Delivery

Michael

Date: 8/4/06